

Suite 2, 92 Cleveland Street Greenslopes, QLD 4120 PO Box 45, Stones Corner, QLD 4120 Tel. +61 (0)7 3015 7555

CERTIFICATE OF ANALYSIS

Asbestos Identification

Certificate No: 18-3663

Client: Central Queensland University **Date Sampled:** 2-07-2018 **Client Contact: Grant Farrell Date Received:** 3-07-2018 0407 760 770 **Date Analysed:** 3-07-2018 Telephone: Email: g.farrell@cqu.edu.au Order No.: CQU0088

Address: Building 37 Sampled By: As Received

554, 700 Yaamba Road Norman Gardens QLD 4701

Site: ROK Building 19

Test Method:

Qualitative identification of asbestos types in bulk samples at COHLABS Laboratory by polarised light microscopy, including dispersion staining techniques using COHLABS in-house method ID-1, AS4964 (2004). The results contained within this report relate only to the sample(s) submitted for testing. COHLABS accepts no responsibility for the initial collection, packaging or transportation of samples submitted by external persons. This document may not be reproduced except in full.

Lab ID	Sample ID	Sample Details	Sample Type	Size / Weight cm/g	Asbestos Present	Fibres Identified
001	CQU0089	Bld 19, ground floor, fascia, north entrance, right side	Fibre Cement	5 x 2	No	NAD, ORF
002	CQU0090	Bld 19, level 3, fascia, east side fire exit	Fibre Cement	6 x 4	No	NAD, ORF
003	CQU0091	Bld 19, ground floor, south entrance, dome sheeting	Fibre Cement	4 x 2	No	NAD, ORF
004	CQU0092	Bld 19, level 3, balcony, soffit sheeting	Fibre Cement	8 x 8	No	NAD, ORF

Fibre Identification Legend

CHR Chrysotile (white asbestos) ORF Organic Fibre Amosite (Brown/Grey asbestos) SMF Synthetic Mineral Fibre **AMO** CRO Crocidolite (Blue asbestos) NFD No Fibres Detected Unknown Mineral Fibre UMF NAD No Asbestos Detected

Approved Identifier

Michael Shepherd

Name:

Approved Signatory

Name: Michael Shepherd

Samples are routinely disposed of approximately 1 month from receipt. Requests for longer term sample storage must be received in writing.