

## Asbestos Bulk Sample Analysis Report Certificate No CER1802131537

|                        |  |                                |               |
|------------------------|--|--------------------------------|---------------|
| <b>Client:</b>         | CQ University Rockhampton                              | <b>Sampled By:</b>             | John Saunders |
| <b>Client Contact:</b> | Grant Farrell  | <b># of Samples Submitted:</b> | 3             |
| <b>Telephone:</b>      | (07) 4930 9241   | <b>Sampling Date:</b>          | 08/02/2018    |
| <b>Email:</b>          | <a href="mailto:facmg@cqu.edu.au">facmg@cqu.edu.au</a> | <b>Date Received:</b>          | 13/02/2018    |
| <b>Project:</b>        | -  | <b>Identification Date:</b>    | 14/02/2018    |
| <b>Site Location:</b>  | Building 363 CQIRP                                     | <b>Issue Date:</b>             | 14/02/2018    |

**Test Methodology:** Polarized light microscopy examination including dispersion staining techniques for the presence of asbestos in accordance with the methodology outlined in the In-House Procedure QP-930-001 which is based on Australian Standard (AS4964-2004)

| Sample ID | Sample Location                   | Sample Description    | Approximate Size or Weight | Asbestos Detected (Yes/No) | Fibre Types Detected |
|-----------|-----------------------------------|-----------------------|----------------------------|----------------------------|----------------------|
| CQU 83    | Debris from floor grate cold room | Dust                  | 48 gms                     | Yes                        | CHR-ORG              |
| CQU 84    | Dividing wall sheeting            | Fibre cement sheeting | 25x20x1mm                  | Yes                        | CHR                  |
| CQU 85    | Wall with ex fans                 | Fibre cement sheeting | 30x20x1mm                  | Yes                        | CHR                  |

Detection limit (AS 4964) – 0.1 g/kg




**Approved Identifier:** Shipra Saha Singh

**Report Approved By:** Ginna Camacho

### Fibre Types

|     |   |     |                                      |
|-----|---|-----|--------------------------------------|
| CHR | Chrysotile (white asbestos) fibres detected     | ORG | Organic fibres detected              |
| AMO | Amosite (brown / grey asbestos) fibres detected | SMF | Synthetic mineral fibres detected    |
| CRO | Crocidolite (blue asbestos) fibres detected     | UMF | Unidentified mineral fibres detected |
| NFD | No fibres detected                              | NAD | No Asbestos Detected                 |

**Notes:** Hand-picked refers to small discrete amounts of asbestos distributed unevenly in a large body of non-asbestos material. Due to their nature, confirmation using another independent analytical technique is recommended if no asbestos is detected in samples of vinyl tiles, bituminous materials, mastics, adhesives, paints, sealants, resins or ore. The results contained within this report relate only to the sample(s) submitted for analysis and OCTIEF accepts no responsibility for the collection, packaging and transportation of sample submitted by external parties. Sample descriptions, sizes and weights are approximate only.